THE POOLS OF THE CITY OF LOS ANGELES Condition Report - July 2004



Facility Hours Of Operation: 2004



Council District 13 Echo Shallow Pool 1632 Bellevue Ave Los Angeles 90026

Built: 1912 Rebuilt: 1956 and 1962 Capacity: 180 people

> Summer of 2003: The pool served 8,333 patrons.

Median Household Income of the Area: \$30,383

Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Holiday
11AM TO	11AM TO	11AM TO	11AM TO	11AM TO	12PM TO	12PM TO	1PM-5PM
5PM	5PM	5PM	5PM	5PM;	6PM	6PM	

Programs:

Facility Features:	SEASONAL POOL (OUTDOOR/ UNHEATED)	
Other Programs:	JUNIOR LIFEGUARD TRAINING SWIM LESSONS (GROUP, PRIVATE, SEMI-PRIVATE, PARENT, CHILD)	

In 2002, Recreation and Parks Facility Repair Division refurbished the locker rooms, showers, and restrooms for this pool, at a cost of \$321,000. However, the pool is located adjacent to the 101 Freeway and should be moved for health and safety reasons. It is not ADA compliant.

Echo Shallow Pool - Immediate Repairs Needed				
1	400' of chain link fencing	\$4,000		
2	Paint and caulk pool	\$55,000		
ТС	DTAL	\$59,000		

THE POOLS OF THE CITY OF LOS ANGELES Condition Report - July 2004



Facility Hours Of Operation: 2004

Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Holiday
11AM TO 3PM; 4PM TO 8PM	11AM TO 3PM; 4PM TO 8PM	11AM TO 3PM; 4PM TO 8PM	11AM TO 3PM; 4PM TO 8PM	11AM TO 3PM; 4PM TO 8PM	1PM TO 6PM	1PM TO 6PM	1PM- 5PM
Programs:							
Facility Featu	Facility Features: YR ROUND POOL (OUTDOOR/ HEATED)						
Sports Programs: NOVICE INNER TUBE WATER POLO NOVICE SPRINGBOARD DIVE TEAM NOVICE SYNCHRONIZED SWIM TEAM NOVICE SWIM TEAM WATER POLO							
Other Programs: LIFEGUARD TRAINING PROGRAM SWIM LESSONS (YOUTH/ ADULTS, PARENT/CHILD) JUNIOR LIFEGUARD TRAINING AQUACISE							

This site, rebuilt in 1981, requires new equipment, pool deck and drains, a new sewer line, and major refurbishment to the bathhouse including upgrades to comply with ADA.

Glas	Glassell Pool – Immediate Repairs Needed					
1	Paint and caulk pool tank	\$55,000				
2	Lighting throughout building	\$8,000				
3	Pump; filter; heater system-by contractor	\$150,000				
4	Replace deck	\$180,000				
5	Install new sewer line from the backwash pit to the street	\$75,000 BOE estimate				
6	Ladders, anchors, lifeguard towers, diving board stands	\$20,000				
7	Refurbish bath house: paint (interior and exterior),	\$100,000				
	plumbing fixtures, tile, floors, doors and partitions.					
	TOTAL	\$588,000				

THE POOLS OF THE CITY OF LOS ANGELES Condition Report - July 2004



Chronie Conde

Council District 13 Hollywood Pool 1122 Cole Avenue Los Angeles 90038

Built: 1950 Capacity: 450 people

Summer of 2003: The pool served 20,725 patrons.

Median Household Income of the Area: \$20,342

Holiday Monday Tuesday Wednesday Thursday Friday Saturday Sunday 11AM TO **11AM TO** 11AM TO 11AM TO 11AM TO 12PM TO 12PM 1PM-5PM 3PM; 4PM 3PM; 4PM 3PM; 4PM TO 3PM; 4PM 3PM; 4PM 6PM TO 6PM 7PM TO 7PM TO 7PM TO 7PM TO 7PM Programs: SEASONAL POOL (OUTDOOR/ UNHEATED) Facility Features: Special Features: WATER SLIDE Sports Programs: NOVICE INNER TUBE WATER POLO NOVICE SWIM TEAM SYNCHRONIZED SWIMMING Other Programs: SWIM LESSONS

This pool was built in 1950 and was re-piped by Recreation and Parks Facility Repair Division, which also added new pumps, filters, and gutters, in 1994. However, the deck has cracked and needs replacement. The bathhouse requires a complete renovation and improvements to meet ADA standards. The Department also installed a waterslide in 2002, two years ago, which improved attendance.

Hollywood Pool – Immediate Repairs Needed				
1	Paint and caulk pool tank	\$55,000		
2	Improve interior lighting and upgrade one deck	\$3,500		
	light pole			
3	Electrical panels and controls	\$10,000		
4	Replace deck and deck drains	\$185,000		
5	Replace top filter manifold	\$4,500		
6	Ladders, anchors, lifeguard towers, and other	\$20,000		
	hardware			
7	Paint interior and exterior of building	\$47,500		
8	Bathhouse refurbishment	?		
TC	DTAL	\$325,500		